

試驗報告

報告編號: HB-14-00938X

C-14-03296

頁 數: 1

OF

報告日期:103年 02月 06日

委 託 位: 博宇德工程股份有限公司

樣 品 名 稱: 隔音墊

送 員:博宇德工程股份有限公司(李友雯)

期: 103年 01月 29日 收 件 H 期: 103年 02月 06日 試

備

註: 1. 以上資料由顧客提供(收件及試驗日期除外)

2. 除非另有說明,此報告結果僅對測試之樣品負責 未經本公司事先書面同意,此報告不可部分複製

試驗結果:

試驗項目	試驗方法	試樣編號	試驗結果	破壞位置
接著強度(kgf/cm²)	參考 CNS 10639(1983)	1	5. 3	隔音墊與水泥 砂漿墊塊介面

註:1. 試樣由顧客提供

2. 試樣描述:

隔音墊(約 4cmX4cmX1cm)以 PU 膠黏貼於水泥砂漿塊(約 7cmX7cm×2cm)上, 黏貼面積約 4cmX4cm

規範要求值僅供參考,合格之判定以委託單位實際要求為準。

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested. This test report cannot be reproduced, except in full, without prior written permission of the Company. 除非另有說明,此報告結果僅對測試之樣品負責。本報告未經本公司書面許可,不可部份複製。

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at www.sgs.com/terms and conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/en/Terms-and-Conditions/Terms-e-Document. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

TWA 9 3 3 7 2 9 6